

I. Records.

Complete copies of all data, records and reports that are submitted to DEP, including but not limited to the items listed below, shall be provided simultaneously (either in hard copy or transmitted electronically) to the Mayor and the Commissioner of the City of Brockton's Department of Public Works:

- (a) Continuous Emissions Monitoring System ("CEMS") data;
- (b) Excess emission reports;
- (c) Compliance stack test reports as required to be submitted to DEP by the final Title V Operating Permit for the facility;
- (d) Any report, notification, compliance certification, or other communication submitted to DEP; and
- (e) The Community Air Monitoring Plan for monitoring and abating air and noise impacts during the period of project construction.

II. Air modeling.

BPC will confirm compliance with applicable air quality standards by utilizing a revised air modeling report based upon the five (5) most recent available years of representative National Weather Service surface and upper air observations meteorological data from Taunton, MA. BPC shall determine the location and magnitude of maximum air quality impacts per DEP and EPA modeling guidance and shall include cumulative impact modeling with the City's Advanced Wastewater Reclamation Facility.

III. Operations.

Other than during an actual emergency/black-out or by order of the grid operator, ISO-NE, Inc. (or a successor) or a governmental agency, the emergency/"black-start" generators shall not be operated, except for up to 100 hours per year of readiness and maintenance testing.

Other than during an actual fire, the emergency fire pump shall not be operated except for up to 100 hours per year of readiness and maintenance testing.

BPC shall not seek permission from DEP to use coal as fuel.